

NYCServ Violation Copy

Internet



00691387R



SUMMONS FOR CIVIL PENALTIES ONLY



000691387R

SUMMONS NUMBER: 000691387R

ENFORCEMENT AGENCY NAME: DEPT. OF ENVIRONMENTAL PROTECTION

DIVISION: Air & Noise Enforcement

AGENCY CONTACT INFORMATION

RESPONDENT:	80 RICHARDS OWNER, LLC	DBA:
MAILING ADDRESS:	80 Richards Street Brooklyn, NY 11231	ID NUMBER: CB032913 TYPE OF ID AND ISSUED BY:
DATE OF OCCURRENCE:	9/27/2024	TIME OF OCCURRENCE: 10:45 AM
PLACE OF OCCURRENCE:	80 Richards Street	BOROUGH: BK

The respondent is summoned to appear and respond to the details of violation(s) stated below.

HEARING DATE: 12/4/2024 TIME: 9:00 AM

OFFICE OF ADMINISTRATIVE TRIALS AND HEARINGS
66 John Street, 10th Floor, New York, NY 10007

FOR HEARING OPTIONS, SEE THE BACK OF THIS PAGE

REFER TO THE SUMMONS NUMBER ABOVE ON ALL CORRESPONDENCE

WARNING: If you do not show up for your hearing (or pay the penalty by mail if permitted) the City will decide the Summons against you and penalties will be imposed. Failure to pay a civil penalty could lead to the denial of an application for, or the suspension, termination or revocation of a city license, permit or registration. In addition, the City may enter a judgment against you in court.

Details of Violation(s)

After investigation, the enforcement agency has found there is a reason to believe that Respondent (the person or entity named on this summons) has violated the following section of Title 24, Chapter 1, of the New York City Administrative Code (Air Pollution Control Code):

DESCRIPTION OF VIOLATION: Respondent failed to renew a Certificate to Operate between 45 & 120 days of its listed expiration date for a boiler with burner. Equipment registered to premise / certificate application #CB032913 was observed to be in use and operation while fueled by natural gas with (#2) grade fuel oil capabilities while the application has a listed 04/25/2020 expiration date.

Infraction Code	Infraction Description
§ 24-123(d)	Application for the renewal of a certificate of operation shall be filed no later than forty-five days and no earlier than one hundred twenty days prior to the expiration of the certificate of operation. - 1st offense

EQUIPMENT / APPARATUS IN VIOLATION: 1) Rockmills, Model #MP-200 boiler with 1) Industrial Combustion, Model #DLG - 84P burner (8.26 million Btu/Hr)

Note: The respondent may have to pay penalties for each charge listed on this violation. The penalties are on the back of this form. The respondent may have to pay penalties for each day during which there is a violation.

NYC Charter Sections 1048 and 1049-a and the Rules of the City of New York authorize the NYC Office of Administrative Trials and Hearings (OATH) to hold hearings. For hearing options, see other side of this notice.

I, an employee of the agency named above, affirm under penalty of perjury that I personally observed the commission of the violation(s) charged above and /or verified their existence through a review of departmental records. False statements made herein are punishable as a Class A Misdemeanor pursuant to section 210.45 of the Penal Law.

Signature: 

Title: Inspector

Print Name: Stephen McKenzie

3

Badge Number: 1549

Agency Code: BAR