NYCServ Violation Copy

Internet

35689824N

NYC Buildings

SUMMONS AND COMMISSIONER'S ORDER• CIVIL PENALTIES APPLY

35689824N

SUMMONS NUMBER: 35689824N

ENFORCEMENT AGENCY: NYC DEPT OF BUILDINGS

AGENCY ADDRESS AND WEBSITE: 280 Broadway, New York, NY 10007 www.nyc.gov/buildings

RESPONDENT: Green House Town Corp. (First Name/Entity, Last)

MAILING ADDRESS: 149-33 Roosevelt Avenue Flushing NY 11354 **DOB License/Registration #:** GC-617287

CELL PHONE: N/A

DATE OF OCCURRENCE: 02/27/2025 **TIME OBSERVED:** 11:30 am/pm

PLACE OF OCCURRENCE: 37-18 138 street **BOROUGH:** Queens

BLOCK: 4978 **LOT** 15 **BIN:** 4624892

You must appear or respond to the details of violation(s) below. For HOW TO RESPOND, see the back of this summons.

HEARING DATE: 5/6/2025 **AT:** ☒ 8:30 am ☐ 10:30 am ☐ 12:30 pm

OFFICE OF ADMINISTRATIVE TRIALS AND HEARINGS: Queens [Borough] (See reverse side for address)
Phone: (844)628-4692

REFER TO THE SUMMONS NUMBER ABOVE ON ALL CORRESPONDENCE.

WARNING: If you do not appear or respond to this Summons, the City will decide the Summons against you and impose penalties. Failure to pay a civil penalty could lead to the denial of an application for, or the suspension, termination or revocation of a City license, permit or registration. In addition, the City may enter a judgment against you in court.

COMMISSIONER'S ORDER TO CORRECT VIOLATION CONDITION(S)

CURE DATE (Zero Penalty Option, if available): 4/28/2025 **Must Appear:** ☐
☐ 1-2 Family Property **Details of Violation(s)** **(If disputing the charge)**

Type of Construction: NB **No. of Stories:** 9 **Vio. Type:** CEU **Dist.** 407 **Code** JL **No.** 01

Occupancy at Time of Inspection: Under Construction. **Complaint#:** (If applicable) **Related Job#** (If applicable)

Based on an inspection of the premises and/or records of the Department, the undersigned has determined that you are in violation of the section of law cited below of the NYC Administrative Code, the NYC Zoning Resolution and/or Titles 1 or 2 of the Rules of the City of New York.

Violating Conditions Observed	Infraction Code	Class	Provision of Law	☐ Recurring Condition-Aggravated I per 1RCNY 102-01(f)	Stop Work/Vacate Order Issued ☐ Full ☑ Partial #
	B282	2	28-105.12.2		

☐ **ILLEGAL CONVERSION—CLASS 1** Per 28-202.1 & 1 RCNY 102-01 additional daily penalties for continued violation of Article 210 of Title 28 also applicable

☐ Per 28-202.1 & 1 RCNY 102-01, additional Class 1 daily or Class 2 monthly penalty may apply ☐ **Aggravated II Condition per 1 RCNY 102-01(f)**

Violation Detail(s): work does not conform to approved Construction documents and/or approved amendments. As Noted At time of Inspection on an active Construction site, 9 story new building form work and rebar working foundation walls and SOE phase. observed at exposure #3(a) pile cap footing with stay form with vertical rebar #6 and the drawings show rebar #8 (b) observed Loop-Coil Tie welded with top rebar of the pile cap footing and the drawings showing Loop Coil tie hooked to Slab rebar. (c) The drawing showing the vertical rebar of stay form space @ 24" Max but at site more then 24" space.

Remedy: work does not conform to approved Construction documents or approved amendments → stop all concrete placement work. provide to CEU@building.nyc.gov full set of approved documents. All TR1 Inspection reports with pics. all TR2 testing compression results.

THE COMMISSIONER ORDERS THAT YOU TIMELY CORRECT THESE CONDITIONS AND FILE A CERTIFICATE OF SUCH CORRECTION. See 1RCNY 102-01 and the reverse for instructions on certifying correction. Uncorrected violations are subject to additional violations and penalties. For certain charges, additional DOB civil penalties may apply pursuant to sections 28-213.1, 28-219.1 and 28-207.2.6 of the Administrative Code. A property owner may be liable for payment of these additional civil penalties even if not cited as respondent on this summons.

NYC Charter Sections 1048 and 1049-a and the Rules of the City of New York authorize the NYC Office of Administrative Trials and Hearings (OATH) to hold hearings. **For hearing options, see other side of this notice.**

Re-Inspection: CEU@buildings.nyc.gov

I, an employee of the Department of Buildings, affirm under penalty of perjury that I personally observed the commission of the violation(s) charged above and/or verified their existence through a review of departmental records. False statements made herein are punishable as a Class A Misdemeanor pursuant to section 210.45 of the Penal Law.

Issuing Officer: John Labib **Signature:** John **Badge#** 3641 **Unit Code:** C 14

35689824N

ORIGINAL - OATH/ECB COPY

ECB-PC (Rev. 8/21)