NYCServ Violation Copy

Internet

37028757R

NYC Buildings

SUMMONS AND COMMISSIONER'S ORDER• CIVIL PENALTIES APPLY

37028757R

SUMMONS NUMBER: 37028757R

ENFORCEMENT AGENCY: NYC DEPT OF BUILDINGS

AGENCY ADDRESS AND WEBSITE: 280 Broadway, New York, NY 10007 http://www.nyc.gov/buildings

RESPONDENT: MB HAMPTONS, LLC (First Name/Entity, Last)

MAILING ADDRESS: 224 W. 30TH ST.
NEW YORK NY 10001-4960

DOB License/Registration #:

CELL PHONE: N/A

DATE OF OCCURRENCE: 6/17/2024

TIME OBSERVED: 10:00 (am)/pm

PLACE OF OCCURRENCE: 224 WEST 30 STREET

BOROUGH: MANHATTAN

BLOCK: 00779 **LOT** 00057 **BIN:** 1014300

You must appear or respond to the details of violation(s) below. For HOW TO RESPOND, see the back of this summons.

HEARING DATE: 09/19/24 **AT:** ☐ 8:30 am ☐ 10:30 am ☑ 12:30 pm

OFFICE OF ADMINISTRATIVE TRIALS AND HEARINGS: MANHATTAN [Borough] (See reverse side for address)
Phone: (844)628-4692

REFER TO THE SUMMONS NUMBER ABOVE ON ALL CORRESPONDENCE.

WARNING: If you do not appear or respond to this Summons, the City will decide the Summons against you and impose penalties. Failure to pay a civil penalty could lead to the denial of an application for, or the suspension, termination or revocation of a City license, permit or registration. In addition, the City may enter a judgment against you in court.

COMMISSIONER'S ORDER TO CORRECT VIOLATION CONDITION(S)

CURE DATE (Zero Penalty Option, if available): N/A **Must Appear:** ☒

☐ 1-2 Family Property **Details of Violation(s)** **(If disputing the charge)**

Type of Construction: **No. of Stories:** **Vio. Type:** CN **Dist.** 105 **Code** CW **No.** 46

Occupancy at Time of Inspection: **Complaint#:** (If applicable) **Related Job #:** (If applicable)

Based on an inspection of the premises and/or records of the Department, the undersigned has determined that you are in violation of the section of law cited below of the NYC Administrative Code, the NYC Zoning Resolution and/or Titles 1 or 2 of the Rules of the City of New York.

Violating Conditions Observed	Infraction Code	Class	Provision of Law	☐ Recurring Condition-Aggravated I per 1RCNY 102-01(f)	Stop Work/Vacate Order Issued ☐ Full ☐ Partial #
	B206	2	27-929.1		

☐ **ILLEGAL CONVERSION—CLASS 1** Per 28-202.1 & 1 RCNY 102-01 additional daily penalties for continued violation of Article 210 of Title 28 also applicable

☐ Per 28-202.1 & 1 RCNY 102-01, additional Class 1 daily or Class 2 monthly penalty may apply ☒ **Aggravated II Condition per 1 RCNY 102-01(f)**

Violation Detail(s): A.C. §27-929.1, FAILURE TO COMPLETE THE INSTALLATION OF A FULL SYSTEM OF AUTOMATIC SPRINKLERS AND FILE A FINAL SPRINKLER REPORT PREPARED BY A REGISTERED DESIGN PROFESSIONAL IN AN OFFICE BUILDING 100 FEET OR MORE IN HEIGHT IN EXISTENCE ON OCTOBER 22, 2004, AS REQUIRED BY THE RETROACTIVE REQUIREMENTS OF LOCAL LAW 26 OF 2004. BUILDING IS CLASSIFIED AS OCCUPANCY GROUP E UNDER THE 1968 CODE. 2014 CONSTRUCTION CODE REQUIRES COMPLIANCE WITH 1968 CODE PROVISION (A.C. §28-201.1 AND §28-204.1) AND 27-929.1 HAS NOT BEEN REPEALED. AS OF 6/17/2024 NO ACCEPTABLE FINAL SPRINKLER REPORT HAD BEEN FILED.

AGG2 HISTORY OF NONCOMPLIANCE ON 37025334L (AGG 2), 37020949P (AGG 2), 37018879X (AGG 1), 37016136X

Remedy: COMPLY WITH 27-929.1 AND INSTALL A FULL SYSTEM OF AUTOMATIC SPRINKLERS AND FILE AN ACCEPTABLE SPRINKLER REPORT.

THE COMMISSIONER ORDERS THAT YOU TIMELY CORRECT THESE CONDITIONS AND FILE A CERTIFICATE OF SUCH CORRECTION. See 1RCNY 102-01 and the reverse for instructions on certifying correction. Uncorrected violations are subject to additional violations and penalties. For certain charges, additional DOB civil penalties may apply pursuant to sections 28-213.1, 28-219.1 and 28-207.2.6 of the Administrative Code. A property owner may be liable for payment of these additional civil penalties even if not cited as respondent on this summons.

NYC Charter Sections 1048 and 1049-a and the Rules of the City of New York authorize the NYC Office of Administrative Trials and Hearings (OATH) to hold hearings. **For hearing options, see other side of this notice.**

I, an employee of the Department of Buildings, affirm under penalty of perjury that I personally observed the commission of the violation(s) charged above and/or verified their existence through a review of departmental records. False statements made herein are punishable as a Class A Misdemeanor pursuant to section 210.45 of the Penal Law.

Issuing Officer: CAROL WALDRON **Signature:** **Badge#** 9993 **Unit Code:** L9

ORIGINAL – OATH/ECB COPY

37028757R

ECB-PC (Rev. 8/21)