

NYCServ Violation Copy

Internet



39097435X

		SUMMONS NUMBER: 039097435X		
SUMMONS AND COMMISSIONER'S ORDER-CIVIL PENALTIES APPLY ENFORCEMENT AGENCY: NYC DEPT OF BUILDINGS AGENCY ADDRESS AND WEBSITE: 280 Broadway, New York, NY 10007 www.nyc.gov/buildings				
RESPONDENT: OCEAN AVENUE JEWISH CENTER, LL		(FIRST NAME/ENTITY, LAST)		
MAILING ADDRESS: 2596 OCEAN AVE. BROOKLYN, NY 11229		DOB LICENSE/REGISTRATION#:		
		CELL PHONE: N/A		
DATE OF OCCURRENCE: 10/16/2023		TIME OBSERVED: 03:25 PM	BOROUGH: Brooklyn	
PLACE OF OCCURRENCE: 2596 OCEAN AVENUE		BLOCK: 07352	LOT: 00029 BIN: 3199765	
You must appear or respond to the details of violation(s) below. For HOW TO RESPOND, see next page.				
HEARING DATE: 10/23/2024 AT: 09:30 AM				
OFFICE OF ADMINISTRATIVE TRIALS AND HEARINGS: Brooklyn (See locations on next page)				
REFER TO THE SUMMONS NUMBER ABOVE ON ALL CORRESPONDENCE.				
WARNING: If you do not appear or respond to this Summons, the City will decide the Summons against you and impose penalties. Failure to pay a civil penalty could lead to the denial of an application for, or the suspension, termination or revocation of a City license, permit or registration. In addition, the City may enter a judgment against you in court.				
COMMISSIONER'S ORDER TO CORRECT VIOLATING CONDITION(S) AND CERTIFY CORRECTION				
CURE DATE (Zero Penalty Option, if available): Not Applicable		Must Appear: ☒ (If disputing the charge)		
Type of Construction: II		No. of Stories: 3	Elevator Device#: 3P11362	
Occupancy at Time of Inspection: Vacant Lot		Related Job#: N/A	Basis of Violation: 3927405	
Based on an inspection of the premises or the records of the Department, the undersigned has determined that you are in violation of the section of law cited below of the NYC Administrative Code, the NYC Zoning Resolution and/or Titles 1 or 2 of the Rules of the City of New York.				
Violating Conditions Observed				
Infraction Code	Class	Provision of Law	Standard Penalty	Maximum Penalty
B151	Class 1	28-304.1	\$1,250	\$6,250
☐ Recurring Condition Aggravated I per 1RCNY 102-01(f)	☐ Aggravated II Condition per 1 RCNY 102-01(f)	☐ FILE APPLICATION & OBTAIN PERMIT	☐ Per 28-202.1 & 1 RCNY 102-01, additional Class 1 daily or Class 2 monthly penalty may apply.	☐ CEASE USE
Elevator Part / Violating Condition / Suggested Remedy: CLASS 2: REPAIR IN-CAR EMERGENCY PHONE VOLUME(VOLUME TOO LOW TO HEAR)., PROVIDE UP TO DATE ELEVATOR MAINTENANCE LOG BOOK (LAST ENTRY 08/2023)., REMOVE OIL FROM PIT., SERVICE AND TAG MOTOR ROOM FIRE EXTINGUISHER (TAG EXPIRED 07/01/2023)CLASS 1: No Door Lock Monitoring installed in this controller as mandated by 3.10.12 of Appendix K3 of the 2014 NYCBC. This is a controller feature which ensures passenger safety. Remedy; File application, install DLM and, perform and file test with NYCDOB.; Maintain elevator/conveying system;				
THE COMMISSIONER ORDERS THAT YOU TIMELY CORRECT THESE CONDITIONS AND FILE A CERTIFICATE OF SUCH CORRECTION. See 1RCNY 102-01 and the instructions on certifying correction. Uncorrected violations are subject to additional violations and penalties. For certain charges, additional DOB civil penalties may apply pursuant to sections 28-213.1, 28-219.1 and 28-207.2.6 of the Administrative Code. A property owner may be liable for payment of these additional civil penalties even if not cited as respondent on this summons.				
NYC Charter Sections 1048 and 1049-a and the Rules of the City of New York authorize the NYC Office of Administrative Trials and Hearings (OATH) to hold hearings. For hearing options, see other side of this notice.				
I, an employee of the Department of Buildings, affirm under penalty of perjury that I personally observed the commission of the violation(s) charged above and/or verified their existence through a review of departmental records. False statements made herein are punishable as a Class A Misdemeanor pursuant to section 210.45 of the Penal Law.				
Issuing Officer: J Matthews		Signature: Electronically Signed by J Matthews 10/16/2023 04:08 PM	Badge#: 2974	Unit Code: EL