NYCServ Violation Copy

Internet

39135081M

NYC Buildings

SUMMONS NUMBER: 039135081M

SUMMONS AND COMMISSIONER'S ORDER•CIVIL PENALTIES APPLY
ENFORCEMENT AGENCY: NYC DEPT OF BUILDINGS
AGENCY ADDRESS AND WEBSITE: 280 Broadway, New York, NY 10007 **www.nyc.gov/buildings**

RESPONDENT: GOULD HOTEL ON WEST 40TH STREE **(FIRST NAME/ENTITY, LAST)**

MAILING ADDRESS: 60 CUTTERMILL RD. STE 303 GREAT NECK, NY 11021-3104

DOB LICENSE/REGISTRATION#:

CELL PHONE: N/A

DATE OF OCCURRENCE: 01/09/2025 **TIME OBSERVED:** 03:40 PM **BOROUGH:** Manhattan

PLACE OF OCCURRENCE: 342 WEST 40 STREET **BLOCK:** 00763 **LOT:** 00065 **BIN:** 1088524

You must appear or respond to the details of violation(s) below. For HOW TO RESPOND, see next page.

HEARING DATE: 03/20/2025 **AT:** 09:30 AM

OFFICE OF ADMINISTRATIVE TRIALS AND HEARINGS: Manhattan (See locations on next page)

REFER TO THE SUMMONS NUMBER ABOVE ON ALL CORRESPONDENCE.

WARNING: If you do not appear or respond to this Summons, the City will decide the Summons against you and impose penalties. Failure to pay a civil penalty could lead to the denial of an application for, or the suspension, termination or revocation of a City license, permit or registration. In addition, the City may enter a judgment against you in court.

COMMISSIONER'S ORDER TO CORRECT VIOLATING CONDITION(S) AND CERTIFY CORRECTION

CURE DATE (Zero Penalty Option, if available): Not Applicable **Must Appear:** ☑ **(If disputing the charge)**

Type of Construction: 2 **No. of Stories:** C-32 **Elevator Device#:** 1P45540

Occupancy at Time of Inspection: Commercial **Related Job#:** N/A **Basis of Violation:** 1685144

Based on an inspection of the premises or the records of the Department, the undersigned has determined that you are in violation of the section of law cited below of the NYC Administrative Code, the NYC Zoning Resolution and/or Titles 1 or 2 of the Rules of the City of New York.

Violating Conditions Observed

Infraction Code	Class	Provision of Law	Standard Penalty	Maximum Penalty
B151	Class 1	28-304.1	$1,250	$6,250

☐ **Recurring Condition Aggravated I per 1RCNY 102-01(f)**	☐ **Aggravated II Condition per 1 RCNY 102-01(f)**	☐ **FILE APPLICATION & OBTAIN PERMIT**	☐ Per 28-202.1 & 1 RCNY 102-01, additional Class 1 daily or Class 2 monthly penalty may apply.	☑ **CEASE USE**

Elevator Part / Violating Condition / Suggested Remedy: 5/L/10 class 1 .car cease use , car door restrictor is not working repair or replace, 2/x/10 out side comm is not working repair.; Maintain elevator/conveying system;

THE COMMISSIONER ORDERS THAT YOU TIMELY CORRECT THESE CONDITIONS AND FILE A CERTIFICATE OF SUCH CORRECTION. See 1RCNY 102-01 and the instructions on certifying correction. Uncorrected violations are subject to additional violations and penalties. For certain charges, additional DOB civil penalties may apply pursuant to sections 28-213.1, 28-219.1 and 28-207.2.6 of the Administrative Code. A property owner may be liable for payment of these additional civil penalties even if not cited as respondent on this summons.

NYC Charter Sections 1048 and 1049-a and the Rules of the City of New York authorize the NYC Office of Administrative Trials and Hearings (OATH) to hold hearings. **For hearing options, see other side of this notice.**

I, an employee of the Department of Buildings, affirm under penalty of perjury that I personally observed the commission of the violation(s) charged above and/or verified their existence through a review of departmental records. False statements made herein are punishable as a Class A Misdemeanor pursuant to section 210.45 of the Penal Law.

Issuing Officer: M Persaud **Signature:** Electronically Signed by M Persaud 01/09/2025 03:50 PM **Badge#:** 2767 **Unit Code:** EL