

NYCServ Violation Copy

Internet



51011086L

NYC Environmental Protection	SUMMONS - FOR CIVIL PENALTIES ONLY	
051011086L		
SUMMONS NUMBER: 051011086L		
ENFORCEMENT AGENCY NAME: DEPARTMENT OF ENVIRONMENTAL PROTECTION		
DIVISION: <u>ASBESTOS CONTROL PROGRAM</u>		
AGENCY CONTACT INFORMATION: <u>(718) 595-3679</u>		
Respondent:	<u>PACIFIC STONE & BRICKS LLC</u>	BASIS OF INSPECTION: ACP5 NO: <u>31260530</u>
MAILING ADDRESS:	<u>1486 Fulton Street, Ste 1</u> <u>Brooklyn, NY, 11216</u>	ID NUMBER: _____
CELL PHONE:	_____	TYPE OF ID AND ISSUED BY: _____
LICENSE TYPE:	_____	CAPACITY: <u>Building Owner</u>
DATE OF OCCURRENCE:	<u>8/26/2025</u>	LICENSE NUMBER: _____
PLACE OF OCCURRENCE:	<u>1355 Jefferson Avenue,</u> <u>Brooklyn, 11221</u>	TIME OF OCCURRENCE: <u>09:55 AM</u>
		BOROUGH: <u>Brooklyn</u>
The respondent is summoned to appear and respond to the details of the violation(s) stated below:		
HEARING DATE: <u>2/6/2026</u> TIME: <u>09:30 AM</u>		
HEARING LOCATION: OFFICE OF ADMINISTRATIVE TRIALS AND HEARINGS 66 John Street, 10th Floor New York, NY 10007 Phone: (844) 628-4692		
FOR HEARING OPTIONS, SEE THE BACK OF THE PAGE		
REFER TO THE SUMMONS NUMBER ABOVE ON ALL CORRESPONDENCE		
Warning: If you do not respond, the City of New York will decide the Summons against you and impose penalties. If you do not pay an imposed civil penalty, the City of New York could deny an application for, suspend, terminate, or revoke any City license, permit or registration that you have. The City may also enter a judgement against you in court.		
After Investigation, the Petitioner has found there is reason to believe that Respondent (the person or entity named on this notice) has violated:		
Title 24, Chapter 1, New York City Administrative Code (Air Pollution Control Code) sections:		
Title 15, Chapter 1, Rules of the City of New York		
15 RCNY 1-25(C) BX1R Failed to file Asbestos Project Notification 7 days before work starts		
15 RCNY 1-51(C) BX22 Failed to wear proper PPE while in work area.		
15 RCNY 1-51(G) BX27 Failed to post asbestos warning signs at all approaches to work place		
15 RCNY 1-82(A) BX4R Failed to provide or locate worker decon outside work area as required		
15 RCNY 1-102(A) BX5Y Failed to perform removal of ACM by wet methods.		
15 RCNY 1-102(D) BX51 Failed to bag ACM directly upon detachment from substrate as specified		
15 RCNY 1-36(a) BX12 Failed to retain independent third party air monitor		
SECOND OFFENSE (LIST SUBSECTIONS): _____		
Note: The respondent may have to pay penalties for each charge listed on this violation. The penalties are on the back of this form. The respondent may have to pay penalties for each day during which there is a violation.		
The maximum civil penalty which may be imposed for each infraction of Title 15, Chapter 1 of the Rules of the City of New York is \$10,000. NYC Charter Sections 1048 and 1049- and the Rules of the City of New York authorize the NYC Office of Administrative Trials and Hearings (OATH) to hold hearings. For hearing options, see other side of this notice.		
I, an employee of the agency named above, affirm under penalty of perjury that I personally observed the commission of the violation(s) charged above and/or verified their existence through a review of departmental records. False statements made herein are punishable as a Class A Misdemeanor pursuant to section 210.45 of the Penal Law.		
Signature:		
Print Name:	<u>Henry Ermer / 1699</u>	Rank/Title: <u>Inspector</u> Agency Code: <u>ASB</u>